

LAKE AND POND REMEDIATION, INC.

&

CHARLES AQUACULTURE, LLC

15350 N US Highway 301 Citra, FL 32113

LAPR Office: 352-595-8863

Fish farm Office: 352-595-1700

Service Report

Date: December 18, 2023

Biologist: Doug & Kaycee Charles

Client: Palencia, Marsh Creek CDD

Ratings: 1 – 10 (Best is 10)

Waterways: 32 ponds

Herbicides used: Aluminum sulfate

Lake Y-2: Rated: 7

- Spotty floating Microcystin in north cove only.
- Water level high from recent rains.



Treatment: We launched the boat and treated the Microcystin with 50 lbs. of Alum.

Recommendations: Monitor Microcystin and treat as necessary.

Lake I-1: Rated: 8

- Minor Microcystin in Northwest corner of lake.
- Water level high from recent rains.



Treatment: We launched the boat and treated the Microcystin with 50 lbs. of Alum.
Recommendations: Monitor the Microcystin and treat as needed.